

M.P.STATEELECTRICITY BOARD: UJJAIN REGION

CAPACITYWISE NO.OFFAILURE OF TRANSFORMERS OF UJJAIN REGION. FOR APRIL.'2007

S.No	Name of circle	No of X-Mers installed	No of transformer failed during the year up to the month	No of transformer replaced during the year up to the month	% failure w. r. t. no of X-mer installed at the beginning of the year	No of X-mers where more than 7 days time taken for replacement	stock of transformer at the end of reporting month
1	UJJAIN	11778	5	5	4.00%	---	
2	DEWAS	6255	8	1	0.13%	Nil	Nil
3	SHJAPUR	5508	7	0	0.13%	7	0
4	RATLAM	5620	24	14	0.43%	0	0
5	MANDSAUR	8552	0	0	0.00%	0	0
6	NEEMUCH	2644	13	11	0.49%	3	2
	TOTAL	40357	57	31	0.14%	10	NIL